



Bleck Engineering Company Inc.

professional engineers

February 16, 1976

Mr. Martin L. Cassell, Chairman
Plan Commission
Village of Barrington Hills
112 Algonquin Road
Barrington, Illinois 60010

Re: Mizock's Estates
Subdivision

Dear Mr. Cassell:

The second review of the preliminary plat of subdivision for Mizock's Estates showed the following items from our letter of February 5th have not been complied with at this date:

Item 2. Bearings are not shown on the subdivisions boundary.

DONE

Item 7. Property lines are not at right angles to the straight street lines or radial to curved street lines.

Allowed -

We also noted a ten feet wide public utility easement has been indicated across the lots within the subdivision and one lot outside the subdivision. We bring your attention to the fact that the easement across the lot outside the subdivision will require a separate document to perpetuate the easement.

Very truly yours,

BLECK ENGINEERING CO., INC.

R. E. Lenzini

R. E. Lenzini, P.E.

REL:db

cc: Mr. Phillip P. Mizock
1490 Miner Street
Des Plaines, Illinois 60016

*The 6-1-76
Certificate*